

Katrina Koshivos

RECEIVED TOWN CLERK
GRAFTON, MA

From: Nancy Connors
Sent: Monday, April 08, 2019 12:20 PM
To: ZBA@graffton-ma.gov
Subject: Case #859 / 54 Providence Road

2019 APR -8 PM 2:36

R

The proposed addition to the existing garage must be 10 feet from the septic tank and 20 feet from the leach field.

Thank you.....

Grafton Health Department

Nancy Connors

Office Manager

Town of Grafton

Health Department

30 Providence Road

Grafton, MA 01519

Phone: 508-839-5335 X 1119

Fax: 508-839-8559

connorsn@graffton-ma.gov

www.graffton-ma.gov

Follow Us: [Facebook](#) | [Twitter](#)

When responding, please remember the Secretary of State considers e-mail a public record.

♻️ Consider the environment before printing this e-mail.

RECEIVED
APR 08 2019
Zoning Board of Appeals